



Cable ID: PAIR 4: FIBER A

Test Summary: PASS

Date / Time: 04/12/2004 12:52:55pm
Headroom: 0.75 dB (Loss)
Test Limit: TIA568B Fiber Horiz
 Cable Type: Multimode 62.5

Operator: ADAMS, JOHN QUINCY
 Software Version: 0.6000

Model: DTX-1800
 Main S/N: KT1002

Loss (R->M) PASS

Date / Time: 04/12/2004 12:52:55pm
 Cable Type: Multimode 62.5
 Tester: DTX-1800 (KT1002 v0.6000)
 Module: DTX-MFM (8582057)

Propagation Delay (ns)	106	
Length (ft)	71	PASS
Limit 295		
Result	850 nm	1300 nm
Loss (dB)	PASS	PASS
Loss Limit (dB)	1.16	1.25
Loss Margin (dB)	2.00	2.00
	0.84	0.75
Reference (dBm)	-21.68	-22.56

n = 1.4719
 Number of Adapters: 3
 Number of Splices: 2
 Patch Type: Multimode 62.5
 Patch Length1 (ft): 6.6
 Patch Length2 (ft): 6.6
 Patch Length3 (ft): 0.6
 Reference Date: 04/12/2004 12:50:00pm
 Method B

Compliant Network Standards:

- | | | |
|-------------------------|---------------------|------------------------|
| FDDI | 10BASE-FL | 100BASE-FX |
| 1000BASE-SX | 1000BASE-LX | 10GBASE-S |
| TokenRing 4 Fiber Optic | ATM 52 Fiber Optic | ATM 155 Fiber Optic |
| ATM 155SWL Fiber Optic | ATM 622 Fiber Optic | ATM 622SWL Fiber Optic |
| Fibre Channel 133 | Fibre Channel 266 | Fibre Channel 266SWL |