



Cable ID: WILLOW CREEK FIBE 10

Test Summary: PASS

Date / Time: 12/12/2007 12:34:09pm
Headroom: 0.01 dB (Loss)
Test Limit: TIA 568B Fiber FTA410/20
Cable Type: Multimode 50.0 μ m

Operator: GLENN
Software Version: 1.925
Limits Version: 5.17

Model: DSP-4300
Main S/N: 7527022
Remote S/N: 7527022
Main Adapter: FTA 410
Remote Adapter: FTA 410

n = 1.4725

Number of Adapters: 2
Number of Splices: N/A

Propagation Delay (ns) 304
Length (ft), Limit 6562 203 PASS

Direction	B-A	B-A
Wavelength (nm)	850	1300
Result	PASS	PASS
Loss (dB)	1.56	1.58
Loss Limit (dB)	1.72	1.59
Loss Margin (dB)	0.16	0.01
Reference (dBm)	-21.81	-22.19
12/12/2007 12:13:03pm		

Near End Adapter S/N: 7661040

Far End Adapter S/N: 7661041

Compliant Network Standards:
FDDI
1000BASE-SX
ATM 52 Fiber Optic
ATM 622 Fiber Optic
Fibre Channel 266

10BASE-FL
1000BASE-LX
ATM 155 Fiber Optic
ATM 622SWL Fiber Optic
Fibre Channel 266SWL

100BASE-FX
TokenRing 4 Fiber Optic
ATM 155SWL Fiber Optic
Fibre Channel 133